



-NOTES-
 All pipe lines are figured large enough to take care of future expansion of buildings.
 Pump and storage tank sufficient to take care of 24,000 Gal. during a 10 Hour rush period.
 Pressure tank 6,000 Gal. Capacity to operate between 30 & 45 pounds pressure.
 4 Drinking fountains to be set along lines - Locations to be determined on the ground.

E-99

U.S. DEPARTMENT OF THE INTERIOR		STATE OF MICHIGAN	
NATIONAL PARK SERVICE		MUSKEGON STATE PARK S.P. No. 5	
STATE PARK		WATER SYSTEM	
EMERGENCY		PROJECT No. 31 a-b-c	
CONSERVATION WORK		DESIGNER H.C. MAC SWAIN	CHECKED BY
DATE	DATE DR. 1-4-35	DATE	DATE
CHECKED BY	DISTRICT OFFICER	PROCUREMENT OFFICER	ALLOTMENT AVAILABLE \$
DATE	DATE	DATE	DATE
RECOMMENDED FOR CONSTRUCTION	DISTRICT OFFICE ENGINEER	SUBMITTED BY	SHEET No. 1 of 4
DATE	DATE	SUPT. STATE PARKS	FILE No.
APPROVED FOR CONSTRUCTION	DISTRICT INSPECTOR	APPROVED	MICH. CONSERVATION COMM.
DATE	DATE	DATE	DATE

Revised 1-21-35 H.C.M.