



SEE D-18260 FOR MACHINE LOCATIONS.

**REBAR, MOTOR STARTERS & PUMPS CONTROL CABINETS BY MINDY DENVER**

NOTE: ALL CONDUIT, FITTINGS, WIRE, FEED RACKWAY, 200 AMP 3P S/W, 40 AMP LOAD CENTER, & BLDG. CIRCUITS FURNISHED BY CONTRACTOR.

USE COMMON GROUND FOR ALL EQUIP. GROUNDING NEUTRAL OF 5-KVA CESSARY. GROUNDING TO MEET N.E.C. CODE.

DATE: \_\_\_\_\_ REVISION: \_\_\_\_\_

**MINDY DENVER INC.**  
3474 15TH AVENUE  
DENVER, COLORADO 80202

REFERENCE: \_\_\_\_\_

DESCRIPTION: \_\_\_\_\_

DATE: \_\_\_\_\_