

RADIATION SCHEDULE

ROOM NO.	ROOM NAME	TYPE	NUMBER	STYLE	DEPTH	LENGTH	HEIGHT	MBH 180° AVG. 20'0" R.O.P.	T'STAT. NO. OF LOCATION	NO. OF ZONE	BLINDOUT SIZE	RETURN SIZE	REMARKS
1	ENTRY	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	
1	ENTRY	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	
2	OFFICE	WALL FIN	5 1/2	7	1/2	11	0	1/4	CORNER	1	3/4	3/4	2 ROW
2	OFFICE	WALL FIN	5 1/2	7	1/2	11	0	1/4	CORNER	1	3/4	3/4	2 ROW
2	OFFICE	WALL FIN	5 1/2	7	1/2	11	0	1/4	CORNER	1	3/4	3/4	2 ROW
3	LIVING ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL
3	LIVING ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL
3	LIVING ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL
3	LIVING ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	
3	LIVING ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	
4	TOILET	CONV.	2	3	6	0	2	3		1	1/2	1/2	
5	BATH	CONV.	2	3	6	0	2	3		1	1/2	1/2	
6	HALL												NO HEAT
7	KITCHEN	WALL FIN	5 1/2	7	1/2	11	0	1/4	CORNER	1	3/4	3/4	2 ROW
8	KITCHEN	WALL FIN	5 1/2	7	1/2	11	0	1/4	CORNER	1	3/4	3/4	2 ROW
9	HALL	CONV.	6	5	3	2	6	3		1	3/4	3/4	
10	LIVING ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL
10	LIVING ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL
10	LIVING ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	
11	KITCHEN	WALL FIN	5 1/2	7	1/2	11	0	1/4	CORNER	1	3/4	3/4	2 ROW
12	BUNK ROOM	CONV.	6	5	3	2	6	3		1	3/4	3/4	
12	BUNK ROOM	CONV.	6	5	3	2	6	3		1	3/4	3/4	
12	BATH	CONV.	6	5	3	2	6	3		1	3/4	3/4	
13	BED ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	
14	BED ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL
15	BATH	CONV.	6	5	3	2	6	3		1	3/4	3/4	
15	BATH	CONV.	6	5	3	2	6	3		1	3/4	3/4	
16	ENTRY	CONV.	6	5	3	2	6	3		1	3/4	3/4	
17	HALL												NO HEAT
18	ENTRY	CONV.	6	5	3	2	6	3		1	3/4	3/4	
19	STOCK ROOM	U.H.	7	2	4			23.1		1	1	1	3/4 CPM, 1500 RPM, 8 GPM. FINAL AIR TEMP - 104.2°F
20	REPAIR SHOP	U.H.	8	0				45.7		1	1 1/4	1 1/4	3/4 CPM, 1500 RPM, 8 GPM. FINAL AIR TEMP - 104.2°F
20	REPAIR SHOP	U.H.	8	0				45.7		1	1 1/4	1 1/4	3/4 CPM, 1500 RPM, 8 GPM. FINAL AIR TEMP - 104.2°F
21	GARAGE												NO HEAT
22	BED ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL
22	BED ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL
23	BED ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL
24	HALL												NO HEAT
25	BATH	CONV.	4	5	3	2	6	3		1	3/4	3/4	
26	LAUNDRY												NO HEAT
27	NEW BED ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL
27	NEW BED ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL
26	NEW BED ROOM	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL
29	NEW OFFICE	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL
29	NEW OFFICE	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL
29	NEW OFFICE	CONV.	2 1/2	4	BASE	6	0	3/4	CORNER	2	1/2	1/2	WALL TO WALL

REVISIONS	DATE	BY
1		
5		
6		

APPROVED	DATE	NO.	DATE	BY
		1		
		2		
		3		

REVIEWED	DATE
ARCHITECTURAL	2-1-42
ENGINEERING	2-1-42
LANDSCAPE	

DESIGNED BY	DATE
W. MIDWAY	2-1-42
DRAWN BY	DATE
W. MIDWAY	2-1-42
CHECKED BY	DATE

