



ALL WATER LINES TO HAVE MINIMUM
OF 42" OF COVER

⊙ PLACE CONG. MARKER, 4" DIA. X 24" LONG WITH
"W" INSCRIBED IN TOP, AT LOCATIONS SHOWN

⊙ DRINKING FOUNTAIN - FOR DETAILS
SEE SHEET 15

POUR CONG. THRUST BLOCK, BEARING
2 3/4" MIN. ON UNDISTURBED SOIL

SURVEYED BY		DRAWN BY Y.P.M.A.		DEPT.	NO.	DATE	BY	REVISIONS	NO.	DATE	BY	REVISIONS	MICHIGAN DEPARTMENT OF CONSERVATION	CAMPGROUND WATER SYSTEM	SHEET NO. _____ OF _____	TAHOQUAMENON FALLS STATE PARK LOWER FALLS CAMPGROUND	
DESIGNED BY		CHECKED BY		DATE	1.				3.						FOR PROJECT NO. _____	SHEET 12 OF 15	PLAN NO. E-117
				DATE	2.				4.								