



NOTES
 1. Concrete pad to be placed on 12\"/>

NOTE
 Use galv. rigid conduit with long sweep elbows. Size of conduit to be as required by the National Electric Code.

NOTES
 1. If primary cables are present in trench, drive pedestal mounting stake into ground before backfilling over primary cable. Tamp backfill to provide support for stake.
 2. Wire or clamp conduit to stake to hold it in place while installing cables and backfilling.

DATE	DESIGNED BY	CHECKED BY
April '65	BOYET	
April '65	COTE	

CONSERVATION COMMISSION APPROVAL	
BY:	DATE:
RECOMMENDED FOR APPROVAL:	DESIGNER
RECOMMENDED FOR APPROVAL:	DATE
SECTION APPROVAL	DATE
BY:	DATE:
MICHIGAN DEPARTMENT OF CONSERVATION	
APPROVED:	DATE
PLANNING NO.:	PROJECT NUMBER: