



CONSTRUCTION NOTES

1. ALL UNDERGROUND PRIMARY LINES WILL HAVE A 36" MINIMUM BURY. SECONDARY LINES TO HAVE 30" MIN BURY.
2. 1" #6 BARE WIRE (GROUND) USED THROUGHOUT ENTIRE SYSTEM EXCEPT TO TOILET BUILDING.
3. PROVIDE ENTRANCE JUNCTION RACK COMPLETE WITH 200 AMP METER SOCKET AND 200 AMP CIRCUIT BREAKER DISTRIBUTION PANELBOARD. RACK TO BE INSTALLED ADJACENT TO PAD MOUNTED TRANSFORMER.
4. THE TRANSFORMER WILL BE SUPPLIED & INSTALLED BY U.P. POWER CO. THE CONCRETE BASE & CONDUIT WITH LONG SWEEP ELBOWS WILL BE FURNISHED & INSTALLED UNDER THIS CONTRACT. CONSTRUCTION DETAILS & DIMENSIONS WILL HAVE TO BE OBTAINED FROM THE POWER CO. BEFORE INSTALLATION.
5. POWER CO. WILL PROVIDE THE TERMINAL POLE WITH JOBYLN. CABLE TERMINALS & INSTALL UNDERGROUND PRIMARY TO TRANSFORMER.
6. DISTRIBUTION PANELBOARD WILL HAVE BRANCH BREAKERS AS FOLLOWS:

BRANCH #1	30 AMP.
" #2	70 "
" #3	70 "
T&S BLDG.	60 "

LEGEND

- 2 OUTLET BOX
- 4 OUTLET BOX

BUILDING COMMITTEE APPROVAL	
BY _____	DATE _____
DESIGN	
RECOMMENDED FOR APPROVAL: <i>J. E. Baker</i>	DATE: 3-19-69
DESIGNER	
RECOMMENDED FOR APPROVAL: <i>S. D. P. 10</i>	DATE: 3-19-69
PROGRAM & POLICY COMMISSION	
DIVISION APPROVAL	
BY: <i>Reddy</i>	DATE: 3-19-69
MICHIGAN DEPARTMENT OF NATURAL RESOURCES	
APPROVED: <i>H. E. ...</i>	DATE: 3-21-69
PLAN NO. _____	PROJECT NUMBER _____ SHEET OF _____

SURVEYED BY	DRAWN BY	NO.	DATE	BY	REVISIONS	NO.	DATE	BY	REVISIONS
DESIGNED BY: <i>R.H.M.</i>	3-69	1.	4-70	<i>D.B.</i>		3.			
CHECKED BY	DATE	2.	4-71	<i>D.B.</i>		4.			