



NOTE
 TANK TO BE MADE OF 10 G.G. TONGAN IRON.
 TANK TO BE OF LAP WELDED CONSTRUCTION
 THROUGHOUT.
 TEST - WATERTIGHT.

PLAN FOR
 5,000 GAL. SEPTIC TANK - S.O.#
 FOR BAY CITY STATE PARK
 MICH. DEPT. OF CONSERVATION
 Scale: $\frac{1}{2} \times \frac{1}{2} = 1-0$
 Date: 3-9-32

16" DIA. MANHOLE
 4- REQ'D PER TANK

DETAILS FOR 6" CONNECTIONS
 2- REQ'D PER TANK

E-17
 Plan No. 213