



- A Mess hall
- B Administration Bld'g
- C Sleeping cabins
- D Leader's cabins
- E Infirmary
- F Fuel and ice storage
- G Garage and tool house
- H Help's quarters
- J Group lodge
- K Craft Bldg.
- L Group latrine
- M Staff and directors quarters
- N Central latrine, wash house, laundry
- O Museum
- P Pump house
- ☉ Drinking fountain
- ⊕ Man hole
- ⊕ Fire hydrant

Building	Toilets	Showers	Faucets
Central latrine	5	6	14
Dining hall	2		14
Staff quarters			1
Infirmary	1	1	1
Crafts shop			1
Unit latrine (4)	3	2	4
Unit lodge (4)			1

Note:
 Every latrine is to be provided with a gate valve and anion.
 Every line to a building shall have a shut off and drain 5 feet outside of the building.
 There shall be a minimum cover of 5 feet and no sharp breaks in grade.
 All 2 and 3 inch pipe to be of cast iron bell and spigot, and remainder to be of galv. wrought iron.

APPROVED BY
 MICHIGAN DEPT. OF HEALTH
Edward A. Fish
 DIRECTOR BUREAU OF ENGINEERING

APPROVED BY

 INSPECTOR

APPROVED BY
 MICHIGAN CONSERVATION COMMISSION
R. B. [Signature]

UNITED STATES
 DEPARTMENT OF THE INTERIOR
 NATIONAL PARK SERVICE
 COOPERATING WITH
 MICHIGAN DEPARTMENT OF CONSERVATION

DRAWN BY: F. J. C. **YANKEE SPRINGS PROJECT** PLAN NO. 90-10A
 DESIGNED BY: F. J. C. **LONG LAKE WATER LINES** SCALE 1" = 80'
 CHECKED BY: F. L. H. **RDP-MI-6** DATE _____

PREPARED BY: _____ DATE 2/11/36
 RECOMMENDED BY: _____ STATE PARK AUTHORITY OR SPONSOR DATE _____
 RECOMMENDED BY: _____ INSPECTOR DATE _____
 APPROVED BY: _____ REGIONAL OFFICER DATE _____
 APPROVED BY: _____ ASSISTANT DIRECTOR DATE _____

JOB # 66 2/11/36

E-110