



of-
E-124
4th SHEET
FRAME TWO OF TWO FRAMES

NOTE: Septic Tanks and Distribution Boxes to be so located in relation to topography of ground that the tile in the Distributing Fields can be laid with tops of tile from 1' to 1 1/2' below ground surface. Length of pipe between Dosing Chambers and Distribution Boxes to be such as will best secure this result.
All Sewer Pipe shall be laid to a minimum depth of 36" Grade of all Sewer Pipe to be not less than 1' in 100'