



ELECTRICAL LEGEND

- ⊗ LIGHT FIXTURE
- ⊙ JUNCTION BOX (FOR EQUIPMENT)
- U.G. UNDERGROUND
- A.F.F. ABOVE FINISHED FLOOR
- C CONDUIT
- CCT CIRCUIT
- GFI GROUND FAULT INTERRUPTER
- W.P. WEATHER PROOF
- CU COPPER
- E.F. EXHAUST FAN

UNDERGROUND ELECT. SERVICE FROM TRANSFORMER TO METER AS DESIGNATED IN SITE ENGINEERING UTILITY PLANS COORDINATE WITH CONSTRUCTION MANAGER (M.I.C.)
 ELECT. METER

LIGHT FIXTURE SCHEDULE						
MARK	MFG.	CATALOG #	DESCRIPTION	LAMPS	DIFFUSERS	REMARKS
"A"	MORGAN EDISON	W2051	MONITOR'S WALL LIGHT	(1) 1/4" 20 MED.	POLYCARBONATE	TRAPPER PROOF
"B"	LEVITON	9075	STD. PORCELAIN FXT.	(1) 100 W	NONE	MOUNT 8'-0" A.F.F.

ELECTRICAL NOTES

1. CIRCUIT NUMBERS REPRESENT SINGLE POLE SPACES AND DO NOT CORRESPOND TO ACTUAL PANEL CIRCUIT NUMBERS DESIGNATED ON PANEL
2. LOADS ON PANEL ARE TO BE BALANCED BY ELECTRICAL CONTRACTOR IN FIELD
3. CONTRACTOR TO PHYSICALLY ARRANGE ALL CIRCUIT BREAKERS WITH LIGHTING CIRCUITS GROUPED AT THE TOP OF PANEL, THEN CONVENIENCE OUTLETS, THEN EQUIPMENT & SPARE SPACES AT BOTTOM OF PANEL.
4. DEVICE BOXES IN PIPE ALLEY TO BE SURFACE MOUNTED, ALL OTHERS TO BE FLUSH MOUNTED
5. ALL WIRING TO BE IN CONDUIT. ALL CONDUIT TO BE CONCEALED FROM VIEW EXCEPT IN PIPE ALLEY.

