



PIPING SCHEDULE
 ALL INTERIOR PUMP DISCHARGE PIPING SHALL BE FLANGED DUCTILE IRON PER SPECIFICATION 15110
 FORCEMAIN - DOWNSTREAM OF THE METER VAULT - SHALL CONFORM TO SPECIFICATION 02717
 ALL VALVES TO OPEN COUNTER-CLOCKWISE

FILE NO: 0134EFP
 PLOT DATE: 1-18-94
 UPDATED BY: PMR

DRN BY: PMR	IDENTIFICATION NO.	ISSUED FOR	DATE
DEST. BY: PMR	PROJECT - ALOHA	PRELIMINARY <input checked="" type="checkbox"/>	11-30-93
CHKD BY: GDA	STATE ACCOUNT	CONSTRUCTION <input checked="" type="checkbox"/>	1-31-94
APPD BY: GDA	607-75-2450-400	FINAL RECORD <input type="checkbox"/>	

CAPITAL CONSULTANTS ENGINEERS

STATE OF MICHIGAN
 DEPARTMENT OF MANAGEMENT AND BUDGET
Office of Facilities

QUALITY OF LIFE RECREATION BOND
 MICHIGAN DEPARTMENT OF NATURAL RESOURCES
 PARKS DIVISION - STATE ACCT. NO: 607-75-2450-400

ALOHA STATE PARK
 EFFLUENT PUMP STATION DETAILS

SCALE: AS SHOWN
 PROJ. NO.: 90134
 SHEET 11 OF 13

L-116